AUBURN HILLS

Site Specifications

STRUCTURAL DETAILS

YEAR BUILT	1994
NUMBER OF FLOORS	2
STRUCTURE TYPE	Steel & Concrete
CEILING HEIGHT	10 FT.
FLOOD PLAIN	> 500/Year
FLOOR LOADING CAPACITY	150 PSF
FLOOR TYPE	Concrete

SITE POWER

ELECTRICAL SUPPLY	DTE
AVAILABLE BUILDING POWER	1.5M 480V 3p

ENVIRONMENTAL CONTROLS

CEU COUNT	7
CEU TYPE	In-Row DX
TOTAL COOLING (DC ONLY)	120 Tons
REDUNDANT	Yes, N+2
VENDOR	Date Aire
MONITORING CONTROLS	Yes (+Rack Inlet Temp)
UPS	Eaton
UPS SIZE	275 kva
BATTERY TYPE & MAKE	C & D Absorbed Glass Mat
BATTERY RUNTIME	10 Minutes
POWER DISTRIBUTION	Liebert
DISTRIBUTION TRANSFORMER TYPE	K-13
GENERATOR	Taylor Power
GENERATOR SIZE	500 KW (1.0 PF)
FUEL TYPE	Diesel
AVAILABLE POWER	120 VAC, 208 VAC 3-Phase
DIESEL SUPPLY ON-SITE	72 Hr
PRIORITY FUEL SUPPLY	Yes

CUSTOMER SUPPORT

REMOTE HANDS	Yes
CUSTOMER SUPPORT	+1 248 247 3000 support@qsgit.com
SALES	+1 248 247 3000 sales@qsgit.com

FIRE PROTECTION

FIRE PROTECTION	Multi-zone
FIRE SUPPRESSION	Multi-stage, zoned, Localized dry pipe
REMOTELY MONITORED	Yes

CONNECTIVITY

MEET-ME-ROOM	Yes
NETWORK NEUTRAL	Yes
DIVERSE FIBER ENTRANCE	Yes
FIBER CROSS CONNECTS	Yes
COPPER CROSS CONNECTS	Yes, special order
IP SERVICE	Special order

SECURITY DETAILS

CCTV	Yes
CCTV RECORDS	> 90 Days
CARD ACCESS	HID
ACCESS CONTROLS	Mag. Lock +Tamper Detection
BIOMETRIC	Yes

CERTIFICATIONS